

Extinguishing System Attachments

COMPANY

Chief Technologies L L C

PO Box 667

Douglasville, PA 19518 United States

S36642

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet pipe, paddle type

Model	Size In.	Pipe Schedule	Max System Pressure psig
CF-WFD	2	10 thru 40	450
CF-WFD	2.5	10 thru 40	450
CF-WFD	3	10 thru 40	450
CF-WFD	4	10 thru 40	450
CF-WFD	5	10 thru 40	450
CF-WFD	6	10 thru 40	450
CF-WFD	8	10 thru 40	450
CF-WFD	10	10 thru 40	300

SUPERVISORY SIGNAL INITIATING DEVICES

Supervisory switches

Model	Oper Pressure psig	Max System Pressure psig
CF-OSYSU-1	N/A	N/A
CF-OSYSU-2	N/A	N/A

Last Updated on 2022-08-05

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."