

## Waterflow Alarm Valves

Waterflow alarm valves (alarm check valves) are installed in either vertical or horizontal positions in wetpipe sprinkler systems to sound a fire alarm gong when a flow of water from the system equals or exceeds that of a single sprinkler. They are designed for use with hydraulic or electric gongs or both.

There are two designs, the differential type and the pilot valve type. The differential type has a rubber-faced clapper with an annular groove in the seat; the pilot valve type has a metal-faced clapper with a pilot valve attached to the clapper arm.

A retard chamber, which minimizes false alarms due to surges and fluctuations in water supply pressure, may be supplied with the alarm valve. If a retard chamber is supplied, *only the listed chamber for a specific manufacturer and valve model shall be used*. Alarm valves are FM Approved with specific trim, and no substitutes or omissions in part or in full are allowed.

Alarms are tested by flowing water through the system test pipe. Pilot valves may be field-adjusted to assure alarm reliability. Unless otherwise noted in the listing, these valves have 175 psi (1205 kPa) rated working pressure.

## Models CF-100A, CF-100B and CF-100C

### Product Specification

Model No	Description	Valve Size		Rated Working Pressure		End Connection	Remarks
		in	(mm)	psi	(kPa)		
CF-100A	Alarm Check Valve	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Flanged x Flanged	a, b, c, d, e
CF-100B	Alarm Check Valve	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Flanged x Grooved	a, b, c, d, e
CF-100C	Alarm Check Valve	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Grooved x Grooved	a, b, c, d, e

#### Remarks:

a. Resilient seat.

b. Only considered FM Approved when supplied with Model WPS10-1 water pressure alarm switch

c. Only considered FM Approved when supplied with Winters Model PFE3933R1 or WIKA Model 111.10SP.100 pressure gauges (inlet and outlet)

d. Only considered FM Approved when supplied with Model RC-16 retard chamber

e. FM Approved for Vertical Installations Only

<b>Company Name:</b>	Chief Technologies, LLC
<b>Company Address:</b>	P.O. Box 667, Douglasville, Pennsylvania 19518, USA
<b>Company Website:</b>	<a href="http://chief-fire.com">http://chief-fire.com</a>
<b>New/Updated Product Listing:</b>	No
<b>Listing Country:</b>	United States of America
<b>Certification Type:</b>	FM Approved
<b>Class of Work:</b>	1041-Alarm Check Valves