



MAIL TYPE
Workflow Transmittal

MAIL NUMBER
PAR-WTRAN-014005

REFERENCE NUMBER
PAR-WTRAN-014005

Final (WF-009481) 4800000312-MOB-Material Technical Submittal-CHIEF FIRE-Fire Hydrant Post Indicator-AI Shamela

From Mr Stephen Rogerson - SAUDI ARABIAN PARSONS LIMITED

To (3) Mr Osama Zeyadeh - SAUDI ARABIAN PARSONS LIMITED
Mr Stephen Rogerson - SAUDI ARABIAN PARSONS LIMITED
Mr NIC.DC Parsons - SAUDI ARABIAN PARSONS LIMITED

Cc (7) Mr 4800000312 MOB - Mobco
NEOM Regional DC - NEOM - Projects
Mr Fahad Abushama - NEOM - Projects
Mr Jonido Pinon - NEOM - Projects
Mr Assim Hamed - SAUDI ARABIAN PARSONS LIMITED
Mr Sujit Jose - SAUDI ARABIAN PARSONS LIMITED
Mr John Montgomerie - SAUDI ARABIAN PARSONS LIMITED

Sent Sunday, 12 December 2021

MESSAGE

Workflow Review History

The attached documents have completed the "4800000312-MOB-Material Technical Submittal-CHIEF FIRE-Fire Hydrant Post Indicator-AI Shamela" workflow with the following results :

This transmittal was automatically generated.

Doc No	Step	Participant	Review Outcome	Comments
03-330000-4800000312-MOB-MEC-MAT-000015	PMC Eng. Review	O Zeyadeh	B - Incorporate Comments - Proceed	We have no objection on the proposed manufacturer The contractor shall submit drawings showing where these items are going to be used and shall indicate the selected valve type, diameter and pressure rating in accordance with the approved design and project specifications. The fire hydrant shall be in accordance with the Civil Defense requirements
	PMC Q&E Review	S Rogerson	B - Incorporate Comments - Proceed	1) No Compliance Sheet. 2) MSF (page 1) incomplete and incorrectly signed by MOBCO. 3) There are 4No. Products submitted in this MAT; each Product /

Material shall be submitted separately.
4) No UL Certificates submitted. 5) No FM Certificates submitted. 5) No ISO 9001 Certificate. 6) No PQD for this Manufacturer. 7) AL SHAMELA shall be defined / described e.g. Agent, Distributor, and evidence shall be submitted they are Approved by Manufacturer, Chief Fire. PQD or similar Submittal may be required for AL SHAMELA.