

# Certificate of Compliance

This certificate is issued for the following:

## Steel Pipe for Automatic Fire Sprinkler Systems

**CFWP (Sch-40) Schedule 40 Steel Pipe  
Rated Working Pressure of 300 psi (2070 kPa)**

**Prepared for:**

Chief Technologies, LLC  
P.O. Box 667  
Douglasville, Pennsylvania 19518  
United States of America


Approval Standard: FM 1630 (June 2021)

Approval Identification: PR475368

Approval Granted: 30 January 2026

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062

